

- 1 Q. Will any upgrading work be required on the section of transmission line from  
2 Western Avalon to St. John's if the Labrador Infeed does not proceed? If yes,  
3 describe the required upgrading.  
4  
5  
6 A. No upgrading will be required in this scenario.

1 Q. Has a report been completed on the entire 230kV transmission system from Bay  
2 d’Espoir to St. John’s to identify the required upgrading for the Isolated Island  
3 Option and for the Labrador Infeed scenario. If yes, provide a copy. If not, why not?  
4

5  
6 A. The analysis to support the required upgrades is provided in Exhibit 24, *“Island  
7 Transmission Outlook”*. Confidential Exhibit CE-10, *“HVdc Sensitivity Studies”*, and  
8 Exhibit 114 *“Upgrade Transmission Line Corridor Bay d’Espoir to Western Avalon”*  
9 provide additional detail for the required upgrades to the 230 kV transmission  
10 system east of Bay d’Espoir. These analyses are based on the assumption that  
11 previous works, including the installation of the shunt capacitor bank at Come By  
12 Chance, are completed.  
13

14 The Island Transmission Outlook is updated on an annual basis to confirm the  
15 requirement and timing of transmission expansion plans previously identified and  
16 to identify longer term expansions that should be incorporated into the 20 year  
17 capital plan. For the Bay d’Espoir- East system, with the exception of those  
18 identified in the Exhibits referenced above, no further upgrades are required during  
19 the planning horizon. Any upgrades to the 230 kV system east of Soldiers Pond /  
20 Holyrood beyond the planning horizon would be common to both expansion plans,  
21 and would not affect the relative CPW difference between the Interconnected  
22 Island and Isolated Island expansion plans.

1 Q. Pg. 28 of the Report referred to in PUB-Nalcor-151 refers to a full import of 475 MW  
2 from the Maritimes under the Labrador Infeed scenario during the loss of the HVdc  
3 link between Labrador and the Island. What improvements, if any, would be  
4 required to the transmission system west of Bay d’Espoir to accommodate the full  
5 import of 475 MW from the Maritimes, what are the anticipated further capital  
6 expenditures associated with these improvements and will they be included in the  
7 cost of the Maritime Link?

8

9

10 A. While the Maritime Link is capable of importing 475 MW into Bottom Brook, Nalcor  
11 has used a 300 MW import from Nova Scotia in its analysis with the Maritime Link  
12 in service. Please refer to the 300 MW import referenced in Table 3 in Exhibit 106.

13

14 No upgrades to the system west of Bay d’Espoir beyond those contemplated to  
15 interconnect the Maritime Link are required to accommodate this level of import  
16 from Nova Scotia, and therefore no further capital expenditures are anticipated  
17 beyond those required to interconnect the Maritime Link. The costs required to  
18 interconnect the Maritime Link are included in the cost of the Maritime Link.

1 Q. Pg. 3 of Exhibit 105 states: *“While Hydro does not have a formal transmission*  
2 *planning criteria consistent with NERC transmission planning standards TPL-001*  
3 *through TPL-006, most, if not all, of the procedures used in planning Hydro’s*  
4 *transmission system are comparable to those used by other utilities. This Planning*  
5 *Manual documents the current transmission planning practices used and the tests*  
6 *applied to verify these practices. The Planning Manual also serves as a first step*  
7 *towards the development of a formal criteria.”*

8

9 When does Nalcor anticipate completion of the development of its formal  
10 transmission planning criteria?

11

12

13 A. The establishment of a framework for reliability oversight is within the purview of  
14 the Government of Newfoundland and Labrador. As indicated in the *Energy Plan*<sup>1</sup>,  
15 the Government of Newfoundland and Labrador will “monitor the development of  
16 standards of practices in the North American electricity industry, particularly  
17 market rules, transmission access rules and reliability oversight. This will ensure we  
18 are prepared to appropriately adopt these practices when we become more  
19 electrically integrated.”

20

21 Once the Province establishes a process for introducing reliability oversight, Nalcor  
22 will prepare formal criteria as required by that process.

---

<sup>1</sup> *Energy Plan*, page 47.

1 Q. With reference to pg. 13 of Exhibit 106, should the phrase “0.38 and 4.9 pole  
2 outages per year” be “0.16 and 4.9 pole outages per year”?

3  
4  
5 A. Nalcor believes the phrase “0.38 and 4.9 pole outages per year” to be appropriate.  
6 Table 5 from the CIGRE report<sup>1</sup> discussed in Exhibit 106 is reproduced below  
7 (emphasis added):

(B) 2 Terminal Systems - 1 Converter per Pole

System	2007				2008				Years	Average to 2008			
	Pole		Bipole		Pole		Bipole			Pole		Bipole	
	f <sub>p</sub>	d <sub>p</sub>	f <sub>b</sub>	d <sub>b</sub>	f <sub>p</sub>	d <sub>p</sub>	f <sub>b</sub>	d <sub>b</sub>		f <sub>p</sub>	d <sub>p</sub>	f <sub>b</sub>	d <sub>b</sub>
Skagerrak 1 & 2	1.25	3.1	0.00	0.0	2.00	3.8	0.50	1.0	20	1.54	17.1	0.13	1.03
Skagerrak 3 (1)	1.00	1503.2	-	-	0.50	4360.4	-	-	15	1.53	484.2	-	-
Square Butte	1.00	4.1	1.50	0.3	5.25	0.8	0.00	0.0	18	2.85	6.2	0.42	2.27
CU	0.50	23.8	0.00	0.0	1.25	58.5	0.00	0.0	20	1.71	4.6	0.28	1.66
Gotland 2 & 3	0.25	0.8	0.00	0.0	0.50	46.6	0.00	0.0	20	0.38	35.8	0.20	1.49
Fennoskan (1)	2.00	14.2	-	-	1.50	46.4	-	-	19	2.26	10.1	-	-
SACOI (3)	3.33	1.7	-	-	1.67	2.5	-	-	16	4.90	2.6	-	-
New Zealand Pole 2 (3)	2.50	4.3	-	-	0.50	0.7	-	-	17	1.65	2.7	-	-
Kontek (1)	0.50	2.7	-	-	1.00	32.0	-	-	7	0.86	15.7	-	-
SwePol (1)	0.50	2.4	-	-	2.00	1.7	-	-	8	3.56	21.0	-	-
Kii Channel	0.00	0.0	0.00	0.0	0.00	0.0	0.00	0.0	8	0.16	99.6	0.00	0.00
Grita (1)	4.00	42.2	-	-	4.5	9.3	-	-	5	2.70	17.1	-	-

8  
9  
10 The Kii Channel system has demonstrated excellent performance during the eight  
11 years of operation reported in Table 5, and while the table indicates a pole outage  
12 rate ranging between 0.16 and 4.9 outages per year, Nalcor is of the opinion that  
13 operating experience from systems with longer operating history may be a better  
14 indicator of long-term performance. For systems with 15 or more years of operating  
15 history, the range is between 0.38 and 4.90 outages per year.

<sup>1</sup> CIGRE B4\_2009\_2010 “A Survey of the Reliability of HVdc Systems Throughout the World During 2007 – 2008”, by M.G. Bennett, N.S. Dhaliwal, A. Leirbukt, CIGRE 2010

- 1 Please note Nalcor compared the upper end of the pole outage range (9.8 pole
- 2 outages on a bipole system) to the rule of thumb of one pole outage per 100 km per
- 3 year, but has not relied on the lower end of the range in its analysis.

1 Q. On pg. 21 of Exhibit 106, in reference to the corridor for 230 kV lines, TL202 and  
2 TL206, it is stated: *“It is difficult to determine the exact return period due to the lack  
3 of meteorological data along the corridor, loading data on the transmission lines,  
4 and actual line failures of TL202 and TL206. Based upon the analysis completed for  
5 the Avalon Upgrades and the lack of a structural failure on either TL202 or TL206, it  
6 is assumed that the design of each line is in the order of 1:25 years.”*

7  
8 The table on pg. 155 of Exhibit 85 clearly shows a structural failure of both TL202  
9 and TL206 in February, 1970, due to wind and ice.

10  
11 Please explain this discrepancy.

12  
13  
14 A. The structural failure that occurred on TL202/206 in February 1970 occurred at the  
15 eastern end of the transmission line in the vicinity of the Sunnyside Terminal  
16 station. This area, which is exposed to meteorological conditions similar to those  
17 experienced elsewhere in the Avalon area, is not indicative of the conditions  
18 experienced on the remainder of the transmission line route for TL202/206.

19  
20 Table 2.1 of Exhibit 85 provides the design wind and ice loads for the Bay d’Espoir  
21 project. TL202/206 are in the Normal Zone<sup>1</sup>, so the applicable design criteria are:<sup>2</sup>

Radial Ice in inches (mm)	Gust Wind Speed in mph (km/hr)
1.0 (25)	0 (0)
0.5 (13)	73 (117)
0 (0)	110 (176)

---

<sup>1</sup> Exhibit 85, Figure 2.1, page 35

<sup>2</sup> Exhibit 85, Table 2.1, page 33

1 Exhibit 87 describes an assessment of probabilistic climatic loadings on TL202/206, and  
2 Table 6 of Exhibit 87 indicates that the modeled ice loadings corresponding to a 10, 25,  
3 and 50 year return period are 31, 39, and 45 mm respectively along much of the  
4 TL202/206 route.<sup>3</sup>

5  
6 The design ice loading for TL202/206 corresponds to a modeled 1 in 10 year return period,  
7 but the operating performance of the line (notwithstanding the failure in the Avalon area)  
8 has been good for over 40 years of operation. There is, however, a lack of meteorological  
9 data, a lack of loading data, and also a lack of actual failures along the majority of the  
10 route. Consequently, a 1:25 year return period has been assumed.

---

<sup>3</sup> Referring to Figure 6 of Exhibit 87, much of the route is in the 200 to 250 m elevation range, so the 183 m elevation is selected from Table 6.



1 Q. Further to PUB-Nalcor 166, with the failure data in Exhibit 85, more recent  
2 meteorological data and the analysis completed for the Avalon Upgrades, could an  
3 analysis such as that performed for the Avalon Upgrades be completed for  
4 TL202/206?

5  
6

7 A. Such an analysis for TL202/206 is presented in Exhibit 87. As indicated in Nalcor's  
8 response to PUB-Nalcor-166, the failure data from Exhibit 85 is not useful in this  
9 analysis, as the loading in the area where the 1970 failure occurred is comparable  
10 to that of the Avalon Region.

1 Q. Table 5, Exhibit 106, indicates that the level of unsupplied energy for the Isolated  
2 Island Option varies from 0 MWh to 19,838 MWh for the years 2017 to 2037.  
3 Corresponding figures for the Island Interconnected Option without the Maritime  
4 Link range from 14,384 MWh to 93,744 MWh over the same period. This  
5 demonstrates that over the period 2017 to 2037 the Isolated Island Option has less  
6 unsupplied energy than the Island Interconnected Option without the Maritime  
7 Link.

8

9 Assuming for the moment that the loss of TL202/206 under the Isolated Island  
10 Option and a bipole outage under the Island Interconnected Option without the  
11 Maritime Link for the *“worst 2 week window”* is a reasonable comparison, please  
12 confirm that Table 5 demonstrates that the Isolated Island Option is more reliable  
13 than the Island Interconnected Option without the Maritime Link for the period  
14 2017-2037?

15

16

17 A. While Nalcor agrees that Table 5 of Exhibit 106 indicates the Isolated Island  
18 alternative has less unsupplied energy than the Island Interconnected alternative  
19 without the Maritime Link, Nalcor does not agree with the conclusion that the  
20 Isolated Island alternative is more reliable than the Interconnected Island  
21 alternative without the Maritime Link for the period 2017 to 2037. Further  
22 information and context than is provided in Table 5 would be required to draw such  
23 a conclusion.

24

25 The results presented in Table 5 represent a worst case comparison of the level of  
26 risk of unsupplied energy during extraordinary events in the Isolated Island  
27 alternative and Interconnected Island alternative without the Maritime Link. As

1 indicated in Exhibit 106, the likelihood of an icing event occurring during the worst  
2 2 week period is remote and the level of unsupplied load would be expected to be  
3 less than half of that indicated in Table 5 should an outage due to icing occur.<sup>1</sup>

4  
5 While the Isolated Island expansion plan has considerable investment in thermal  
6 generation on the Avalon Peninsula, thermal units are deployed on the Avalon for  
7 economic rather than reliability reasons.

8  
9 The expansion plans presented for both the Isolated Island and Interconnected  
10 Island alternatives meet all prescribed and accepted criteria for generation planning  
11 and from this perspective both can be considered of comparable reliability with the  
12 Interconnected Island alternative showing a considerable economic preference.

13  
14 Without established criteria setting the level of acceptable risk to unsupplied  
15 energy during extraordinary operating conditions, Exhibit 106 demonstrates both  
16 the Interconnected Island and Isolated Island options perform comparably to or  
17 better than the current system during such conditions. Notwithstanding the level  
18 of performance provided by the current system, Table 6 in Exhibit 106<sup>2</sup> indicates  
19 that the level of unsupplied energy in the Interconnected Island alternative without  
20 the Maritime Link can be decreased through the addition of combustion turbines on  
21 the system, and the “level of exposure can be managed to a preset level by  
22 incremental additions of combustion turbines”<sup>3</sup>.

---

<sup>1</sup> This issue is discussed in Exhibit 106 on pages 26 through 29

<sup>2</sup> Exhibit 106, Page 25

<sup>3</sup> Exhibit 106, Page 24

1 Nalcor has signed a term sheet with Emera for the construction of the Maritime  
2 Link, and therefore believes a comparison between the Isolated Island alternative  
3 and the Interconnected Island alternative with the Maritime Link is reasonable. If,  
4 however, the Maritime Link were not to proceed, and new reliability criteria were  
5 developed that required a lower level of unsupplied energy, then the exposure in  
6 the Interconnected Island expansion plan without the Maritime Link can be reduced  
7 by installing combustion turbines.

8

9 Nalcor therefore disagrees with the conclusion that the Isolated Island alternative is  
10 more reliable than the Interconnected Island alternative.

1 Q. Has Nalcor established a standard for the maximum acceptable limit of unsupplied  
2 energy? If so, please advise this standard. If not, why not?

3

4

5 A. NL Hydro has not established a definitive standard or limit for unsupplied energy.  
6 Instead of a single standard for unsupplied energy, NL Hydro has a Business  
7 Continuity Planning process that assesses both the impact on customers and  
8 likelihood of occurrence of events that could result in unsupplied energy. Based on  
9 this analysis NL Hydro completes an overall risk ranking.

10

11 The impact on customers is measured on the level of unsupplied energy on a scale  
12 of one to five with one being “ business as usual” and five being an unsupplied  
13 energy of greater than 830 MWh. The likelihood of occurrence is also measured on  
14 a scale of one to five with one being “ not very likely” (likelihood of occurrence less  
15 than once in 100 years) and five being “ near certain” (likelihood of occurrence  
16 more than once per year). Based on the impact and likelihood an overall risk  
17 ranking of Low, Medium or High is determined.

18

19R Risks with an overall ranking of High have both high customer impact and high  
20 probably of occurrence and mitigation of these risks takes priority. Medium and  
21 Low risks on the other hand are less severe and these are assessed individually. The  
22 cost of risk mitigation may often out weigh the benefit and when this is the case the  
23 prudent utility view is to develop an emergency response plan to implement in the  
24 rare event of occurrence. Nalcor believes that an assessment of risk, including  
25 both assessment of customer impact and probability, along with the development  
26 of a mitigation plan to address these risks, is an appropriate and prudent alternative  
27 to implementing a single limit for unsupplied energy.

1           The loss of TL 202 and TL 206 in the current operating scenario and the loss of the  
2           Bipole in the Island Interconnected scenario are both High impact Low likelihood  
3           events. The cost of mitigation for either of these events is high and NL Hydro has  
4           opted to accept these risks consistent with its Business Continuity Planning process.

1 Q. Pg. 14, footnote 7 of Exhibit 106, refers to continuous monopolar rating of 552.6  
2 MW. Is this correct? If not, the figure of 702.6 MW is also incorrect.

3

4

5 A. Footnote 7 is incorrect. The correct value for the continuous monopole rating is  
6 530.6 MW, as stated in the last paragraph on page 14 of Exhibit 106. Together with  
7 three combustion turbines, the available capacity is 680.6 MW, which exceeds the  
8 645.7 MW peak deliveries to the Island Interconnected System.

9

10 Footnote 7 should read:

11

12 *The continuous monopolar rating of 530.6 MW plus start up of three 50 MW*  
13 *combustion turbines (Stephenville, Hardwoods and the new unit scheduled for 2014)*  
14 *results in a capacity of 680.6 MW, which exceeds the 645.7 MW Island*  
15 *Interconnected System block thereby eliminating any shortfall.*