

Labrador – Island - Link

Overview

August 8, 2011

Boundless Energy



HVdc LIL - Historical

- 1974-75 Teshmont – Zinder Studies
 - Two ± 400 kV, 800 MW bipoles
 - Gull Island to Soldiers Pond (near St. John's)
 - Gull Island to Stony Brook (central NL)
 - Ability to connect Gull Island Converters and HVdc lines at Stony Brook for reliability
 - Assumptions 11% annual growth rate in load

HVdc LIL - Historical

- 1980 SNC-Lavalin HVdc Study - LCDC
 - Single ± 400 kV, 800 MW bipole (920 MW winter)
 - Gull Island to Soldiers Pond
 - 3 x 100 MVAR or 2 x 150 MVAR synchronous condensers Soldiers Pond
 - Second ± 400 kV, 800 MW bipole (for load growth)
 - Gull Island to Stony Brook (central NL)
 - Ability to connect Gull Island Converters and HVdc lines at Stony Brook for reliability
 - 4 x 100 MVAR synchronous condensers Stony Brook

HVdc LIL - Historical

- 1982 SNC-Lavalin HVdc Study – LCDC
 - Two ± 400 kV, 800 MW bipoles
 - Gull Island to Soldiers Pond (near St. John's)
 - Gull Island to Onslow, NS
 - Taylors Brook Switching Station (west coast of NL) for paralleling of poles for reliability

HVdc LIL - Historical

- 1982 SNC-Lavalin HVdc Study – LCDC (variant)
 - ± 400 kV, 800 MW bipole
 - Muskrat Falls first with 345 kV transmission to Churchill Falls
 - Labrador converter located at Gull Island
 - Newfoundland converter at Soldiers Pond

HVdc LIL - Historical

- 1988 – 89 Hydro-Québec System Studies
 - ± 400 kV, 800 MW bipole
 - Gull Island to Soldiers Pond
 - HQ system
 - Minimal impact for loss of HVdc
 - NL system
 - UFLS for loss of pole
 - Loss of bipole to be studied

HVdc LIL - Historical

- 1998 – 99 Joint NLH HQT Integration Studies
- 1998 – 99 Teshmount HVdc Studies
 - ± 400 kV, 800 MW bipole
 - Gull Island to Soldiers Pond
 - 800 MW (2 pu) rating per pole for 10 minutes
 - 600 MW (1.5 pu) rating per pole continuous
 - Prevent load shedding for transient and permanent pole outages
 - 3 x 150 MVAR synch condensers at Soldiers Pond

HVdc LIL - Historical

- 2008 DC1010 RSW Voltage and Conductor Optimization
 - 800 MW Gull Island to Soldiers Pond with O/L
 - ± 400 kV, single 50.4 mm diameter conductor
 - 1600 MW multi-terminal Gull Island, Soldiers Pond, Salisbury NB with O/L to NL only
 - ± 450 kV, single 58 mm diameter conductor

HVdc LIL - Historical

- 2008 TransGrid Multi-terminal HVdc Study
 - Gull Island, Soldiers Pond, Salisbury NB
 - ± 450 kV transmission voltage
 - Gull Island 1600 MW converter
 - Soldiers Pond 800 MW converter with O/L
 - Salisbury 800 MW converter with no O/L
 - Focus on Island upgrades

HVdc LIL - Historical

- 2008 TransGrid Multi-terminal HVdc Study
 - Case included new 300,000 bbl/day oil refinery
 - 5 x 50 MW combustion turbines
 - 4 x 300 MVAR high inertia synch condensers
 - 50% series compensation of 2 x 230 kV lines
 - Upgrade of 4 x 230 kV lines
 - Modify existing UFLS
 - Implement an SPS

HVdc LIL - Historical

- 2009 NBSO SIS Multi-terminal HVdc at Salisbury, NB
 - Extension of 2008 TransGrid Study
 - ± 450 kV, 1600 MW with 800MW converter at Salisbury
 - Deliveries through NB to Maine border
 - 2 x 125 MVAR sync condensers (ESCR and voltage control)
 - 345 kV transmission reinforcement for firm NB to NL transactions
 - Sudden power reversals must be controlled
 - Potential for NE instability

HVdc LIL - Historical

- 2010 Hatch/TransGrid HVdc System Sensitivity and VSC Risk Analysis (DC1210)
 - Cursory evaluation of VSC technology
 - Cancellation of new refinery
 - VSC ratings acceptable for Soldiers Pond and NB
 - 3 x 150 MVAR high inertia sync condensers
 - New 230 kV line BDE – WAV instead of 50% series compensation

HVdc LIL - Historical

- DC1240 Proximity Study
 - Hatch/Manitoba Research Center
 - Proximity of ± 450 kV HVdc to existing 66 kV, 138 kV and 230 kV AC transmission lines
 - Recommended minimum separation distance

LIL Project Shift in 2010

- 1974 – 2009
 - Gull Island followed by Muskrat Falls
 - ± 400 kV, 800 MW Gull Island to Soldiers Pond, or
 - ± 450 kV, 1600 MW Gull with multi-terminal HVdc
- Early 2010
 - ± 450 kV, 1600 MW Gull with multi-terminal HVdc less than optimal finance/economics

LIL Project Shift in 2010

- Mid 2010
 - Muskrat Falls first 824 MW, 4.9 TWh
 - Meets NL requirements to near 2041
 - ± 320 kV, 900 MW Muskrat Falls to Soldiers Pond potential VSC vs LCC
 - ± 200 kV, 500 MW VSC based system Bottom Brook (NL west coast) to Cape Breton (Lingan, NS)
 - Potential to reduce O/L requirements to NL
 - Path to market for excess power and energy

LIL Project Shift in 2010

- Siemens HVdc PLUS Feasibility Study
 - ± 450 kV, 1600 MW Multi-terminal with VSC at Gull Island and Soldiers Pond
 - Single base case, limited contingencies
 - VSC technology no issue with 230 kV ac faults
 - VSC technology slower recovery for dc faults
 - Need for high inertia sync condensers

LIL Integration Studies - Ongoing

- VSC Screening Study
 - ± 320 kV, 900 MW Island Link, Island model
 - ± 200 kV, 500 MW Maritime Link with their equiv
 - Four base cases, limited contingencies
 - Verify east and west converter interactions
 - ABB PSS/E modeling followed by PSCAD
- SLI integration studies for converter spec's
- Joint Integration studies for ML

LIL Electrodes

- 1998 Teshmont
 - Sea electrode Lake Melville (Labrador)
 - Sea electrode Conception Bay (Newfoundland)
- 2007/08 WTO DC 1110 Statnett
 - Sea electrodes without substantial justification to eliminate other types
- 2009 WTO DC 1250 panel of 5 experts
 - Shoreline pond electrode for Newfoundland
 - Further work for Labrador

LIL Electrodes

- 2010 WTO DC 1500 Hatch
 - Shoreline Pond electrodes both sites

Questions?